



Role of OSW in ISO-NE and NYISO

Executive Findings

December 4, 2025

CRA Charles River
Associates



Charles River Associates is an established boutique consulting firm specializing in high stakes matters for clients across sectors

- **Founded in 1965**
- **1,000+ Consultants today**
- **23 Offices in 10 Countries**
- **Industry Practices:** Energy, Chemicals, Industrials, Metals + Mining, Life Sciences, Financial Services
- **Cross-Industry Practices:** Investigations, Strategy and Governance, Anti-trust

CRA Office Locations




Boston* - New York - Summit NJ - Washington DC - Tallahassee - Chicago - Dallas
Houston - College Station TX - Salt Lake City - Los Angeles - Oakland CA - San Francisco
Toronto - São Paulo - London - Cambridge - Paris - Brussels - Amsterdam - Zurich
Düsseldorf - Munich - Sydney

CRA offers resource planning support to utilities across the country

In recent years, CRA has supported electric, gas and combined IOUs and POU's in more than 30 states to address market forecasting, strategy, and investment planning questions.

States Where CRA Has Recently Supported Utilities in Strategy, Resource and Investment Planning



Client Examples



Executive Summary

Background

Methodology & Base Case

Results: NYISO

Results: ISO-NE

Appendix

IRP-style analysis finds potential benefits from OSW in the Northeast

However, regulators and resource planners should consider further factors including technology risks, capacity prices, and policy uncertainty when selecting a resource mix

1

Reliability risks are imminent in NYC without urgent action

Our findings align with concerns raised by NYISO

2

Portfolios with OSW have the best balance of performance (depending on capital costs)

Portfolios that include OSW drive down energy prices while maintaining or improving reliability but incurred higher capital costs

3

Exposure to region-wide tightening supply-demand

NYISO faces elevated risks if it cannot import from neighboring domestic and Canadian markets, which are also becoming stressed






4

Dependence on assumptions

Results are highly dependent on underlying assumptions, particularly portfolio build-out and ability to import. More analysis needed to understand regional risk

Including OSW resulted in lower energy prices and emissions, while maintaining reliability

Portfolios that include OSW have the most balanced performance and lead on most metrics, except for capital costs which were mixed across markets

Resource Adequacy	Energy price	Natural gas capacity factor	Emissions	Net Capital costs
				



Natural gas



Onshore renewables



Offshore wind




No Alternatives

Winner

Runner-up



Greatest output during **winter hours** when fuel systems and wider markets are stressed



Strategic siting near transmission-constrained urban centers, particularly NYC



All MWs are good MWs
Portfolios without new resources have the worst performance



Native investment mitigates but does not eliminate exposure to region-wide tightness



Executive Summary

Background

Methodology & Base Case

Results: NYISO

Results: ISO-NE

Appendix



Resource adequacy ensures there is enough – and the right kind of – generation

Resource adequacy is one element of maintaining grid reliability.

Resource adequacy ensures the generator portfolio mix can maintain reliability across a wide range of conditions.

If there is insufficient generating capacity in a given hour, operators will perform **load shedding**, intentionally disconnecting load, to maintain the stability of the grid.

Historically, load shedding risks were limited to a small number of peak hours, but it is increasingly spread across a range of hours.

Utility planners are incorporating increasingly complex planning methods to evaluate the resource adequacy of potential generation mixes. These models include the factors listed below.



Generator outages

Planned and unplanned



Load Uncertainty

Weather variability



Renewable variability

Weather variability



Extreme weather

Multi-hour and multi-day events




Common cause outages

Disruptions in fuel supplies




Integrated resource planning (IRP) evaluates risks and benefits of pursuing various generator technology paths



Future looking

Predict load (and shapes), energy, capacity needs, prices, and grid mix




Maintain feasibility

Only consider plans that are possible - given supply chain, land, labor, and tech constraints




Consider grid as a whole

Capture interactions between technologies



Hedge against uncertainty

Consider multiple possible future conditions



Perform Quantitative assessment

Use quantitative and robust modelling and metrics



Balance goals

Balance reliability, affordability, sustainability, and policy targets



Long-term planning


IRP enables policy makers and decision makers to holistically evaluate generator investment decisions



NG fuels systems in New England and New York are uniquely stressed

Challenges	
Limited ability to add new resources	Complex permitting, limited land, and limited fuel make adding new NG generation challenging
Aging fleet	The existing NG and oil fleet is aging. Further stress on these resources could accelerate their retirement.
Competing for fuel	NG generators compete with building heating for fuel. While heating electrification will free up fuel, it also drives up winter electricity demand
Back-up fuel usage	Many NG generators are dual fuel. While using back-up fuel oil maintains resource adequacy, it increases wear, emissions, and costs
Timing mismatch	While investments are on their way to expand fuel systems, may not be soon enough to support imminent RA challenges

There is limited headroom on existing gas infrastructure to add new gas generators with firm contracts in the Northeast




From stakeholder feedback, Gas EPCs state that adding new natural gas resources is more challenging and expensive

Stakeholders pointed at strained supply chains, lengthy permitting process, and limited labor pools as key pain points. Manufacturing capacity is operating close to 90%, and prices have tripled between 2022 and 2025.



NYISO projects elevated risk in coming years, with a shift toward winter risk



Of note, NYISO assumed imports from the Ontario Independent System Operator (IESO), PJM, and Hydro-Québec in its modeling. CRA matched this approach.

However, **all these markets are tightening and collectively shifting risk toward the winter months.** To understand this risk, we performed sensitivities with no imports.



Executive Summary

Background

Methodology & Base Case


Results: NYISO

Results: ISO-NE

Appendix



We use a suite of modeling techniques to identify and evaluate system reliability and cost outcomes





Scenarios enable us to evaluate multiple possible generator technology futures

Base Case (Including OSW) – Expected portfolio mix

Use ISO load forecast, CRA generator portfolio forecast including OSW and no retirements

Goal: Evaluate the current trajectory of the systems

Counterfactual Scenarios

No Alternatives – Base Case with OSW removed

Goal: Evaluate the impact of canceling or delaying OSW, without alternatives

Rationale: Many OSW projects are advanced. There may be limited time to pivot to alternative generator resources, given supply chain and permitting challenges

Renewables Only – Replace with onshore renewables (scaled based on equivalent clean energy)

Goal: Evaluate the performance of OSW relative to inland, onshore renewables

Rationale: Replacing OSW with in-load zone resources may result in worse reliability performance, given transmission congestion and worse alignment with key stress periods

Gas Only – Replace with gas peakers in load zone (scaled on capacity contribution)

Goal: Evaluate the performance of OSW relative to in-zone dispatchable resources

Rationale: NYISO has identified a continued need for dispatchable (gas or DEFR) resources, particularly down-state



We employ a suite of quantitative metrics to evaluate the generator scenarios with respect to reliability, affordability, and sustainability

Normalized Expected unserved energy (N-EUE)

EUE measures the expected amount of energy which is not served in a given year. Normalized EUE (N-EUE) divides the raw EUE by the total energy sales. Reported in parts per million. Computed for 2032 and 2036.

N-EUE and RA premium measure reliability

Energy & net capital price

Energy price computes the expected average market price. Also, produce capital cost estimate.

Computed as a net present value over 2026 to 2044.

Energy and capital price measures affordability

Natural Gas (NG) Capacity Factor

Average annual capacity factor for natural gas plants in the system.

Computed as an average value over 2026 to 2044.

NG capacity factor measures sustainability with leading indicators of reliability

Emissions

The total amount of annual CO2 emissions produced.

Computed as a total value over 2026 to 2044.


Emissions measures sustainability



Adequacy is used to diagnose the likelihood of load shedding events

Loss of Load Analysis


- ✓ AdequacyX mirrors analytical approaches performed by other ISOs
- ✓ Loss of load modeling is focused on identifying the frequency, magnitude, duration, and seasons of load shedding events
- ✓ We matched NYISO's assumptions for Hydro-Quebec, IESO, and PJM. We performed additional sensitivities with no imports





We use synthetic data to simulate the future load conditions that include electrification

NYISO: Simulated Average Monthly Load




Electrification of heating and transit is driving higher load growth in the winter than summer.

In both NYISO and ISO-NE, winter load growth between 2032 and 2036 is over **3x** that of summer growth



Using relationships published by NYISO, we also examine the impact of OSW on the use of liquid back-up fuels (fuel oil) in downstate New York

Estimated Oil-Fired Generation in NYISO Zones F–K



Cold snaps divert gas to heating, pushing generators to liquid, back-up fuels. Liquid fuels drive higher emissions, costs, and maintenance burdens.

OSW can help drive down liquid fuels usage by meeting (some) of the growing winter load

Sources:

1. <https://www.nysrc.org/wp-content/uploads/2025/03/Fuel-Availability-Constraints.pdf>
2. CRA Analysis



Using IRP-style analysis, we use quantitative and holistic modeling to evaluate the risks and benefits of pursuing OSW relative to credible alternatives

Using LTCE, we identify a Base Case outlook that includes OSW. We identify credible counterfactual scenarios if the markets pivot away from OSW.


Using PCM, capital costs, loss of load, and supplemental modelling, we forecast the energy cost, capital costs, natural gas usage, sustainability, resource adequacy of the various scenarios.

Using quantitative metrics, we evaluate each portfolio's reliability, affordability, and sustainability.




Base case for NYISO adds 66 GW of new generation, including 10 GW of OSW, by 2044

Renewable Build Out



NYISO Base Case Portfolio Outlook






NYISO Scenarios (2032)

Scenario	OSW	Solar	Onshore Wind	Storage	Natural Gas
Base Case	2,234 MW	8,058 MW	5,388 MW	1,442 MW	18,971 MW
No Alternatives	-2,096 MW	+0 MW	+0 MW	+0 MW	+0 MW
Renewables Only	-2,096 MW	+725 MW (Upstate)	+3,075 MW (Upstate)	+920 MW (Downstate)	0
Gas Only	-2,030 MW	+0 MW	+0 MW	+0 MW	+637 MW (Downstate)




Base case for ISO-NE adds 44 GW of new generation, including 18 GW of OSW, by 2044

Renewable Build Out



ISO-NE Base Case Portfolio Outlook





ISO-NE Scenarios (2032)

Scenario	OSW	Solar	Onshore Wind	Storage	Natural Gas
Base Case	2,830 MW	6,855 MW	3,078 MW	1,498 MW	14,971 MW
No Alternatives	-2,030 MW	+0 MW	+0 MW	+0 MW	+0 MW
Renewables Only	-2,030 MW	+5,300 (ME, MA, RI, VT)	+925 (ME, MA, RI, NH)	+0 MW	+0 MW
Gas Only	-2,030 MW	+0 MW	+0 MW	+0 MW	+1,621 (Boston, SE MA)



Executive Summary

Background

Methodology & Base Case


Results: NYISO

Results: ISO-NE

Appendix




NYISO: Forecast for average annual power price



Additions of renewables – either onshore or offshore – drives down price while NG or no additions results in price increases




NYISO: Forecast for average annual natural gas capacity factor



Additions of renewables – either onshore or offshore – drives usage of natural gas plants. OSW has the greatest reduction in NG usage due to alignment strong winter generation and siting in constrained zones



NYISO: Forecast for emissions




Reduced reliance on natural gas resources reduces emissions




NYISO: Forecast for oil-fired electricity generation

Estimated Oil-Fired Generation (2032)




Estimated Oil-Fired Generation (2036)



OSW drives down usage of oil-fired generation downstate. Its efficacy increases as winter generation grows. OSW's direct impact declines past ~5GW




How to read results:






NYISO: Resource adequacy outlook (2032) – 99% Worst Load Shedding Outcome


No Alternatives




Renewables Only



Gas Case



Base Case




Summer risk emerges in NYISO without new local additions.

Onshore renewables and gas can help, but OSW provides biggest risk reduction.




NYISO Risk Distributions (with imports)



Risk is overwhelming concentrated downstate with additional risk in Zone A (West). Direct connection of OSW to downstate helps reduce risk downstate.




NYISO Risk Distributions (without imports)



Without imports, risks spread across the state. Downstate would be materially harmed without imports.



NYISO: Forecast for reliability risk



OSW maintains or improves reliability due to strong winter generation in NYC. OSW performance relative to gas is influenced based on the size and technology selected for the alternative gas resource.



Executive Summary

Background

Methodology & Base Case


Results: NYISO

Results: ISO-NE

Appendix




ISO-NE: Forecast for average annual power price



Additions of renewables – either onshore or offshore – drives down price while NG or no additions results in price increases




ISO-NE: Forecast for average annual natural gas capacity factor



Additions of renewables – either onshore or offshore – drives usage of natural gas plants. OSW has the greatest reduction in NG usage due to alignment strong winter generation and siting in constrained zones



ISO-NE: Forecast for emissions



Reduced reliance on natural gas resources reduces emissions



ISO-NE: Forecast for reliability risk


Target
EUE: 20

Study Year	Imports?	Scenario	N-EUE (ppm)
2032	Yes	Base	0
		No Alternatives	0
		Renewables Only	0
		Gas Only	0
2036	Yes	Base	0
		No Alternatives	0
		Renewables Only	0
		Gas Only	0
2032	No (Results are illustrative and reflect highly conservative assumptions)	Base	3.49
		No Alternatives	4.09 (+17%)
		Renewables Only	3.55 (+2%)
		Gas Only	2.63 (24%)

Load shedding risk is minimal, except in case with limited imports. In that case, Gas provides the best performance, but all portfolios are well within risk tolerance. Resource mix exceeds resource adequacy need. Outlook will evolve as ISO-NE's capacity accreditation evolves





Load shedding risk distribution for ISO-NE (no Imports)



Load shedding risk is concentrated in Vermont and Boston



Capital, energy, and resource adequacy premium forecast



Capital costs are mixed and depend on the underlying assumptions including accreditations as well as land, transmission, and pipeline upgrade costs. Capacity costs are assumed to be equal.



The US faces twin resource adequacy and affordability challenges due to aging infrastructure and load growth



Context

Load growth in winter months, the retirement of dispatchable generation, and stress of fuel supplies has created concerns for resource adequacy in Northeast. NYC is of particular concern for near-term reliability risks.




Action

Using IRP-style analyses, the authors provided a quantitative review of the risks and benefits a resource mix that include **OSW** versus credible alternatives.



Findings

Portfolios that include OSW drove down energy prices, usage of natural gas, and emissions while maintaining reliability. OSW portfolios had higher capital costs. NYC faces near-term reliability risks without investment in local generation.



Limits and implications

Capital costs are difficult to forecast. Buildability is also a significant factor in selecting resources. NYISO is exposed to region wide tightening. **Further region-wide modeling and coordination is recommended.**

While there is no one path to a reliable grid, OSW can play a meaningful role. It brings strong winter generation, offers siting advantages near constrained coastal regions, and consistently achieves high ELCC values. However, it may incur higher capital costs depending on local dynamics and learning rates.



Executive Summary

Background

Methodology & Base Case

Results: NYISO

Results: ISO-NE

Appendix



NYISO Scenarios (2036)

Scenario	OSW	Solar	Onshore Wind	Storage	Natural Gas
Base Case	3,314 MW	11,932 MW	8,138 MW	8,842 MW	18,971 MW
No Alternatives	-3,176 MW	0	0	0	0
Renewables Only	-3,176 MW	+1,125 MW (Zones C,F)	+3,950 MW (Zones A, C, E)	+1,310 MW (Zones J, K)	0
Gas Only	-3,176 MW	0	0	0	+751 MW (Zones J, K)



ISO-NE Scenarios (2036)

Scenario	OSW	Solar	Onshore Wind	Storage	Natural Gas
Base Case	8,497 MW	9,400 MW	3,514 MW	3,150 MW	14,971 MW
No Alternatives	−7,697MW	+0 MW	0	0	0
Renewables Only	−7,697MW	+18,350 (ME, MA, RI, VT)	+3,300 (ME, MA, RI, NH)	0	0
Gas Only	−7,697 MW	+0 MW	+0 MW	0	+5,558 (Boston, SE MA)



Resource adequacy is simulated using advanced statistical methods to test against the full range of possible grid conditions

This study evaluates the resource adequacy of the projected generator mix and assesses the impact of potential solutions

- **Load shedding:** The inability to serve demand due to insufficient available generation or transmission
- **Resource Adequacy:** Ensuring the system has enough—and the right type of—generation so that the risk of load shedding remains below an acceptable threshold

Industry best practice is to use models like Monte Carlo Simulation to quantify the risk of load shedding

- **Monte Carlo Simulation:** A way to test how the power grid performs under thousands of possible future scenarios, like rolling the dice many times to test against all possible outcomes
- **Uncertainty:** If there wasn't uncertainty, we could exactly plan the system. However, the exact load (both peak and across all hours), generator availability (due to planned, forced outages, and weather induced outages), wind generation, and solar generation are all unknown



These models are ultimately assessing the frequency, magnitude, duration, and timing of potential load shedding events

The resource adequacy of a proposed portfolios is measured using reliability risk metrics including:

Loss of load expectation (LOLE): Measures how often outages are expected, expressed in days per year with at least one outage event (regardless of size or duration). The typical target is 1 day in 10 years (i.e., 0.1 LOLE)

Expected Unserved Energy (EUE): Measures the total expected megawatt-hours of load shedding in a given year. No fixed target but around **0.001% - 0.003% has been used as an informal target**

Long-short position: A zone is considered **long** when it has surplus capacity and can buy and sell in the market. A **short** zone results in load shedding


Our model focuses solely on the long (negative) or short (positive) reliability balance, without considering economics

Examining the hour of day and month of year of risk can be useful when evaluating potential solutions

For example, solar has minimal benefit to solve risk exposure during Summer evening and winter mornings



CRA follows the dispatch order used by many ISOs



Any remaining shortfall contributes to LOLE & EUE metrics